

WWTP Peracetic Acid Disinfection System Shoreline Substantial Development Permit NOTICE OF DECISION

City File #SL19-0001

Description of Proposal: Shoreline Substantial Development Permit to allow construction of an 80-square-foot chemical metering building with associated mechanical, electrical, and plumbing equipment, in addition to a 200-square-foot canopy structure to contain peracetic acid. The purpose is to transition the City's Wastewater Treatment Plant effluent disinfection system from chlorination to peracetic acid.

Location: 2115 Second Street (parcel #28051300201800)

Proponent: City of Snohomish Public Works

Date of Application: October 3, 2019

Date of Complete Application: October 29, 2019

Date of Notice of Application: November 1, 2019

SEPA Threshold Determination: December 6, 2019

Lead Agency: The City of Snohomish Planning and Development Services Department.

Decision: The Planning Director determined the application is consistent with the applicable permit criteria and grants Shoreline Substantial Development Permit approval, subject to conditions:

1. All debris, overburden and other waste materials from construction shall be disposed of in such a way as to prevent their entry by erosion from drainage, high water or other means into any water body.
2. The development shall comply with the Snohomish County Inadvertent Discovery Plan for cultural resources.
3. All development shall be consistent with the project narrative, plans, and recommendations of the professional studies and reports submitted with the application, as approved the City.

Appeal: The appeal period for this decision is twenty-one (21) days from the date of this notice. Any appeal must be filed in writing with the Snohomish City Clerk at 116 Union Avenue, Snohomish, Washington 98290, accompanied with a filing fee of \$500. A City department, other party of record, or agency with jurisdiction may appeal the Planning Director's decision to the City Hearing Examiner following the procedures contained in Chapter 14.20 SMC, pursuant to SMC 14.250.050.

For Information Contact:
Brooke Eidem, Planner
(360) 282-3167

Date of Notice: January 10, 2020



CITY OF SNOHOMISH

P.O. BOX 1589 | SNOHOMISH, WASHINGTON 98291 | (360) 568-3115 | WWW.SNOHOMISHWA.GOV